

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 388 / A4/2025

Dated: 21.05.2025

It is certified that an inspection team headed by **Mr Gopalan P – Assistant Water Analyst from Tamilnadu Water Supply and Drainage Board** inspected the **Srinivasa Public School, Ganapathypalayam** on **19.05.2025** and on the basis of water test report (attached) bearing No: **TR/2025/51810-1** dated **22.05.2025** of **DWT Lab** certified that the **Srinivasa Public school** has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The certificate is valid till 30.01.2026

Signature with Seal:

Name : **S.K. RAJASHEKAR**

Designation **Public Health Supervisor**

Name & Address of the Office / Department :

**Govt. Primary Health Centre
Erainampatty,
Udumalpet**

To

Srinivasa Public School
Periyakottai Village
Ganapathypalayam
Udumalpet

**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****DISTRICT WATER TESTING LABORATORY****No. 30, Siruvani Nagar Campus, Bharathi Park Road,****Coimbatore – 641043. E-mail: twadlabcbce@gmail.com, Phone: 0422-2437863****TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 51810-1	Report Issue Date :	22.05.2025	Page No : 1 of 1
Invoice Details:	9303/Dt.19.05.2025/Amt.1652/-	ULR No : - NA -		

Client Name & Address	: M/s. Srinivasa Public School, Ganapathypalayam, Udumalpet.			
Contact No / Email.ID				
Sample / Lab No	2025/51810			
Sample Name	: Water - Drinking Water			
Sample Description	: Clear, Colorless, Liquid			
Sample Source	Tap Water (RO)			
Sample Submitted by	: Customer			
Location & Date	: Within the School Premises & 19.05.2025			
Sample Container	: Plastic – Good Condition			
Quantity of Sample Received	: 2 Litre	Sample Condition on Receipt	: Good	
Sample Received on	: 19.05.2025	Environmental Condition Temp °C	: 23 – 27 °C	
Test Commenced on	: 19.05.2025	Test Completed on	: 20.05.2025	

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25°C	--	IS 3025: Part 11: 2022	7.6	6.5-8.5	No Relaxation
2	Total Hardness as CaCO ₃	mg/L	IS 3025: Part 21: 2009 (RA:2023)	22	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	12	200	600
4	Chloride as Cl	mg/L	IS 3025: Part 32: 1988 (RA:2019)	18	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025: (Part 24/Sec 1): 2022 – Turbidity Method	< 5.0	200	400
6	Nitrate as NO ₃	mg/L	IS 3025: (Part 34/Sec-1): 2023 – Screening Method	2	45	No Relaxation
7	Fluoride as F	mg/L	IS 3025: (Part 60/Sec-1): 2023 - SPADNS Method;	< 0.2	1.0	1.5

Remark: The tested sample confirmed to IS: 10500:2012 (RA: 2023) Drinking Water Specification within the permissible Limit in respect to above tested parameters.

---End of Report----

Reviewed and Authorised by

P. Gopalan - Assistant Water Analyst

Assistant Water Analyst
TWAD Board, D.W.T. Lab,
Coimbatore

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

**TAMILNADU WATER SUPPLY AND DRAINAGE BOARD****DISTRICT WATER TESTING LABORATORY****No. 30, Siruvani Nagar Campus, Bharathi Park Road,****Coimbatore – 641043. E-mail: twadlabcbce@gmail.com, Phone: 0422-2437863****TEST REPORT**

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 51810-2	Report Issue Date :	22.05.2025	Page No : 1 of 1
Invoice Details:	9303/Dt.19.05.2025/Amt.1652/-			

Client Name & Address	: M/s. Srinivasa Public School, Ganapathypalayam, Udumalpet.			
Contact No / Email.ID				
Sample / Lab No	2025/51810			
Sample Name	: Water - Drinking Water			
Sample Description	: Clear, Colorless, Liquid			
Sample Source	Tap Water (RO)			
Sample Submitted by	: Customer			
Location & Date	: Within the School Premises & 19.05.2025			
Sample Container	: Plastic – Good Condition			
Quantity of sample Received	: 2 Litre	Sample Condition on Receipt	:	Good
Sample Received On	: 19.05.2025	Environmental Condition Temp °C	:	23 – 27 °C
Test Commenced on	: 19.05.2025	Test Completed on	:	20.05.2025

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Turbidity	NTU	IS 3025: Part 10: 2023	< 0.5	1	5
2	Total Dissolved Solids	mg/L	IS 3025: Part 16: 2023	61	500	2000
3	EC @ 25°C	µS/cm	IS 3025: Part 14: 2013	89	--	--
4	P- Alkalinity as CaCO ₃	mg/L	IS 3025: Part 23: 2023	Nil	--	--
5	Calcium as Ca	mg/L	IS 3025: Part 40: 1991	4	75	200
6	Magnesium as Mg	mg/L	IS 3025: Part 46: 2023	3	30	100
7	Sodium as Na	mg/L	IS 3025: Part 45: 2024	9	--	--
8	Potassium as K	mg/L	IS 3025: Part 45: 2024	< 0.1	--	--

Reviewed and Authorised by
P. Gopalan – Assistant Water Analyst
TWAD Board, D.W.T.Lab.
Coimbatore

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 30, Siruvani Nagar Campus, Bharathi Park Road,

Coimbatore – 641043. E-mail: twadlabcbce@gmail.com, Phone: 0422-2437863

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2025/ 51810-2	Report Issue Date :	22.05.2025	Page No : 2 of 1
Invoice Details:	9303/Dt.19.05.2025/Amt.1652/-			

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2023)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
9	Iron as Fe mg/L	mg/L	IS 3025 (Part 53) : 2024	< 0.1	0.3	No Relaxation
10	Manganese as Mn	mg/L	IS 3025 (Part 59) : 2023	< 0.1	0.1	0.3
11	Ammonia as NH ₃	mg/L	IS 3025 (Part 34) : 2023	< 0.1	0.5	No relaxation
12	Nitrite as NO ₂	mg/L	IS 3025 (Part 34/Sec-1) : 2023	< 0.01	--	--
13	Phosphate as PO ₄	mg/L	IS 3025 (Part 31/Sec-1) : 2022	< 0.1		
14	Oxygen Observed in 4 hrs.as O ₂ (Tidy's Test)	mg/L	IS 3025 (Part 63) : 2007	0.24	--	--
15	Residual Chlorine	mg/L	IS 3025 (Part 26) : 2007	0	0.2	1.0

Bacteriological Test

1	Fecal coliform	CFU / 100 ml	APHA 23 rd Edition 2017 – 2130 B	Absent	Absent/ 100 mL
---	----------------	--------------	---------------------------------------------	--------	----------------

Remark: The tested sample confirmed to IS: 10500:2012 (RA: 2023) Drinking Water Specification within the permissible Limit in respect to above tested parameters.

---End of Report----

Reviewed and Authorised by
P. Gopalakrishnan, Assistant Water Analyst
TWAD Board, D.W.T.Lab,
Coimbatore

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- The test items will not be retained for more than 15 days from the date of issue of the test report.
- The result applied to the sample as received basis.